

# Certificate of Conformity

By the product certificate number:

No. 2622/0478-N-E1-CER

Issued to:

License holder: **Victron Energy B.V.**  
De Paal 35, 1351JG, Almere, Netherlands

Trademark:



Contract number: 802190

It is certified that the product:

Type of generating unit: **Inverter/Charger with UPS functionality**

Models:	MultiPlus-II 48/8000/110-100 230V	MultiPlus-II 48/10000/140-100 230V	MultiPlus-II 48/15000/200-100 230V
<b>Technical Data:</b>			
<b>Nominal power:</b>	8 kVA / 6.4 kW	10 kVA / 8 kW	15.0 kVA / 12.0 kW
<b>Nominal voltage:</b>		AC input: 187-250 V <sub>ac</sub> DC input: 38-66 V <sub>dc</sub> AC output: 220-240 V <sub>ac</sub> DC output: 48 V <sub>dc</sub>	
<b>Nominal frequency:</b>		50 Hz	
<b>Firmware version:</b>	2621502	2627502	2619502
<b>Number of phases:</b>		Single Phase (L/N/PE)	
<b>Isolation Transformer:</b>		Yes	

Is in compliance with the standard:

**IEC 62116: 2014** "Utility-Interconnected photovoltaic inverters – Test procedure of islanding prevention measures."

The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-18 based on the requirements of the UNE-EN ISO/IEC 17065.

This certificate cancels and supersades certificate no. 2622/0478-N-CER.

First issued on: 02<sup>nd</sup> February 2024.

This certificate is valid until: 23<sup>rd</sup> March 2028.

Madrid, 02<sup>nd</sup> February 2024

Daniel Arranz Muñiz  
Certification Manager

