


## DECLARATION OF CONFORMANCE

To whom it may concern:

We, ALTENERGY POWER SYSTEM INC. NO.1 Yatai Road, Jiaying 314050, China, claims that the microinverter models QS1 and YC600 meet the following requirements:

Protection Voltage monitoring(island)				PASS	
	under voltage		over voltage (stage 1)		
Parameter	Voltage	Time [ms]	Voltage	Time [ms]	
Limit	195.5 V	<= 1500 ms	253.0 V	<= 1500 ms	
Trip value	195.5V		253.0V		
Disconnection time[ms]		323ms		295ms	
Reconnection time	>=180 s	240.27s	>=180 s	240.31s	
--	--		over voltage (stage 2)		
Parameter		--	Voltage	Time [ms]	
Limit		--	264.5 V	<= 200 ms	
Trip value		--	264.5V		
Disconnection time[ms]		--		196ms	
Reconnection time		--	>=180 s	240.27s	

Protections Frequency monitoring (island)				PASS	
	under frequency		over frequency		
Parameter	Frequency	Time [ms]	Frequency	Time [ms]	
Limit	47.5Hz	at least 3s	50.5Hz	<= 500ms	
Trip value	47.5Hz		50.5Hz		
Disconnection time[ms]		3310ms		175ms	
Reconnection time	>=180 s	240.34s	>=180 s	240.38s	



Signature  
 June 8, 2020

ALTENERGY POWER SYSTEM INC.  
 NO.1 Yatai Road, Jiaxing 314050, China  
 Web: [www.APsystems.com](http://www.APsystems.com)  
 Tel: +86 573 83986967

昱能科技

NO.1 Yatai Road, Jiaxing, Zhejiang, China  
 浙江省嘉兴市南湖区亚太路1号  
 +86 57383986967 | [APsystems.com](http://APsystems.com)