

# Certificate of Conformity

Certificate Number: CN-PV-210088

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

<b>Applicant:</b>	Shenzhen SOFAR SOLAR Co., Ltd. 401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community, XinAn Street, BaoAn District, Shenzhen, Guangdong. P.R.China.
<b>Product:</b>	Solar Grid-tied Inverter
<b>Ratings &amp; Principle Characteristics:</b>	See appendix of Certificate of Conformity
<b>Model:</b>	SOFAR 3.3KTL-X, SOFAR 4.4KTL-X, SOFAR 5KTL-X, SOFAR 5.5KTL-X, SOFAR 6.6KTL-X, SOFAR 8.8KTL-X, SOFAR 11KTL-X, SOFAR 12KTL-X
<b>Brand Name&lt;s&gt;:</b>	
<b>Tested according to:</b>	RD1699:2011 UNE 206006 IN:2011 UNE 206007-1 IN:2013
<b>Certificate Issuing Office Name &amp; Address:</b>	Intertek Testing Services Ltd. Shanghai West Area, 2 <sup>nd</sup> Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China
<b>Test Report No.&lt;s&gt;:</b>	210305086GZU-001

Additional information in Appendix.



**Signature**

**Certification Manager: Grady Ye**

**Date: 27 April 2021**

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-210088

MODEL	SOFAR 3.3KTL-X	SOFAR 4.4KTL-X	SOFAR 5KTL-X	SOFAR 5.5KTL-X	SOFAR 6.6KTL-X
Max PV voltage	1000Vdc				
MPPT Voltage range	160-960Vdc				
Max. input current	11/11A				
PV Isc	14/14A				
Max power(VA)	3300	4400	5000	5500	6600
Max output current	3×4.8 A	3×6.4 A	3×8.0A	3×8.0 A	3×9.6 A
Output voltage	3W/N/PE 230Vac/400Vac				
Nominal Frequency	50 Hz				
Power Factor	0.8 Leading to 0.8 Lagging				
Ambient Temperature	-25°C - +60°C				
Protection Degree	IP65				
Protection Class	Class I				
MODEL	SOFAR 8.8KTL-X	SOFAR 11KTL-X	SOFAR 12KTL-X		
Max PV voltage	1000Vdc				
MPPT Voltage range	160-960Vdc				
Max. input current	11/11A				
PV Isc	14/14A				
Max power(VA)	8800	11000	13200		
Max output current	3×12.8 A	3×15.9 A	3×19.1 A		
Output voltage	3W/N/PE 230Vac/400Vac				
Nominal Frequency	50 Hz				
Power Factor	0.8 Leading to 0.8 Lagging				
Ambient Temperature	-25°C - +60°C				
Protection Degree	IP65				
Protection Class	Class I				
Software Version	V 1.00				

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.