


4		Vent vale	SYFM12*1.5	1	
3		CABLE GLAND	PG21 SEALING RANGE 13-18mm	10	
2		CABLE GLAND	PG13.5 SEALING RANGE 6.7-12mm	1	
1		CABLE GLAND	MC4 SEALING RANGE 2.5-4mm	40	
number	label	The name of the	specifications	quantity	note
The contract no		Tank no		Factory number	
		BHT-20/10(DC1000V) PV COMBINER BOX			
tag	Change the file no	The signature	The date of	Pattern marker	The proportion
design		standardized		ZBENY 浙江奔一电气有限公司 Zhejiang Benyi Electrical Co., Ltd.	
drawing		Review and approval			
check		approval			
process		The date of			
		Arrangement diagram			



4	QS1-QS10	DC Switch	BYT.2-32 In=32A DC1000V	10	
3	SPD1-SPD10	SPD	BUD-40KA/3P DC1000V	10	
2		DC Fuse Link	OSPV-30 In=15A DC1000V	40	
1	FU	DC Fuse Holder	BR-30 Imax=30A DC1000V	40	
number	label	The name of the	specifications	quantity	note

The contract no		Cabinet No		Factory number	
		BHT-20/10(DC1000V)			
		PV COMBINER BOX			
tag	Change the file no	The signature	date	Pattern marker	The proportion
design		standardized			
drawing		Review and approval			
check		approval			
process		date			
Schematic diagram				ZBENY 浙江奔一电气有限公司 Zhejiang Benyi Electrical Co., Ltd.	