

Certificate of Conformity

No. 2622/0478-N-CER

By the product certificate number:

Issued to:

License holder: **Victron Energy B.V.**
De Paal 35, 1351JG, Almere, Netherlands

Trademark:



Manufacturer:

It is certified that the product:

Type of generating unit: **Inverter/charger with UPS functionality**

Family: **MultiPlus-II**

Tested model: **48/10000/140-100**

Variant model: **48/8000/110-100**

Technical Data:

	48/8000/110-100	48/10000/140-100
Nominal power:	8 kVA / 6.4 kW	10 kVA / 8 kW
Nominal voltage:	AC input: 187-250 V DC input: 38-66 V (48 V battery) AC output: 220-240 V DC output: 48 V	AC input: 187-250 V DC input: 38-66 V (48 V battery) AC output: 220-240 V DC output: 48 V
Nominal frequency:	50 Hz	50 Hz
Firmware version:	2621502	2627502
Number of phases:	1	1
Isolation Transformer:	Yes	Yes

Is in compliance with the standard:

IEC 62116: 2014 "Utility-Interconnected photovoltaic inverters – Test procedure of islanding prevention measures."

The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-18 based on the requirement of the UNE-EN ISO/IEC 17065.

First issued on: 23rd March 2023.

This certificate is valid until: 23rd March 2028.

Madrid, 23rd March 2023

Daniel Arranz Muñiz
Certification Manager

