

CERTIFICADO

de conformidad

Anexo a

Attachment to

No. de registro: AK 50548602 0001-0002
Registration No.

No. de informe: CN2205XD 001
Report No.

Titular de licencia: SolaX Power Network Technology (Zhe jiang) Co., Ltd.
License Holder
No. 288 Shizhu Road, Tonglu Economic Development Zone, Tonglu City,
Zhejiang Province 310000, P.R. China

Tipo de producción: Inversor fotovoltaico conectado a la red
Type of production

Modelo: X3-MGA-xxK-G2 (xx = 40 , 50 , 60)
Model

Versión de firmware: XMEGA V003.00
Firmware version

Estándar: RD 1699:2011
Standards RD661:2007
RD413:2014
UNE 206006 IN:2011
UNE 206007-1 IN:2013
UNE 217001:2020
UNE 217002:2020

Fecha de emisión: 22.06.2022
Date of issue

El certificado de conformidad hace referencia al producto mencionado anteriormente. Esto es para certificar que la muestra se encuentra en conformidad con el requisito de evaluación mencionado anteriormente. Este certificado no implica una evaluación de la producción del producto y no permite el uso de una marca de conformidad TÜV Rheinland.

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Información del inversor <i>Inverter information</i>			
Modelo <i>Model</i>	X3-MGA-40K-G2	X3-MGA-50K-G2	X3-MGA-60K-G2
Potencia nominal CA <i>Nominal AC Power</i>	40000 W	50000 W	60000 W
Tensión nominal CA <i>Nominal AC voltage</i>	3W+(N)+PE, 220/230 V		
Corriente máxima CA <i>Maximal AC current</i>	66.7 A	83.3 A	100 A
Frecuencia nominal <i>Nominal frequency</i>	50/60 Hz		
Rango de tensión MPPT <i>MPPT voltage range</i>	180-1000 Vdc		
Tensión CC máxima <i>Max. DC voltage</i>	1100 V		
Corriente DC máxima <i>Max. DC current</i>	4*32 A	5*32 A	6*32 A
Elemento de control <i>Control device</i>	Controller in Inverter		
Tipo de dispositivo de control <i>Type of control device</i>	Integrated		
Información general del transductor de corriente externo / medidor de potencia ^{*)} <i>General information of external current transductor/ power meter</i>			
Fabricante <i>Manufacturer</i>	Zhejiang Chint Instrument & Meter Co., Ltd		
Modelo <i>Model</i>	DTSU666		
Aplicación <i>Application</i>	3 Phase		
Tensión nominal <i>Nominal voltage</i>	230 Vac		
Corriente máxima <i>Max. current</i>	80A		
Clase de precisión <i>Class of accuracy</i>	Active energy EN 50470-3:Class B		
Tipo de comunicación <i>Type of communication</i>	RS485		
Esquema básico del sistema ^{*)} <i>Basic system diagram</i>			
<p>The diagram illustrates the basic system configuration. A PV array is connected to a DC Distribution Box, which is then connected to the X3-MEGA2 series Inverter. The inverter's AC output is connected to an AC Distribution Box. This AC Distribution Box is connected to a Solax three phase meter, which is in turn connected to Household Distribution Units. Finally, the Household Distribution Units supply power to a Load. The Solax three phase meter is also connected to the Electrical grid.</p>			

*) Para cumplir los requisitos de RD 244/2019, ANEXO I y UNE 217001 IN: 2020, se instalará el dispositivo adicional.
 To fulfill the requirements of RD 244/2019, ANEXO I and UNE 217001 IN: 2020, the additional device shall be installed.